



HEIGHT OF PARAPET TO BE DETERMINED BY ENGINEERING DESIGN

CAP FLASHING CLIPPED TO COUNTER FLASHING

ADDITIONAL FORM SUPPORT AT CEMENT BOARD PANELS AS REQUIRED

MIN. 5/8" (16mm) CEMENT BOARD PANELS TO BE INSTALLED PREPOUR AS FORM PANEL FOR CONCRETE CAP AT TOP OF WALL INSTALLED ON SLOPE TO MATCH ROOF PITCH

MINIMUM 6" (152mm) THICK CONTINUOUS CONCRETE CAP AT TOP OF WALL POURED INTEGRAL WITH FIREWALL OR AS PER LOCAL CODE

CONTINUOUS STEEL ANGLE AS SPECIFIED

EPS CANT STRIP

GYPSUM BOARD FINISHED/FIRE STOP INSTALLED AT JOISTS AS PER CODE

FIBER BOARD SUBSTRATE w/ ROOF MEMBRANE ON 3 1/2" (89mm) RIGID INSULATION

U BRACKET ANCHOR INSERT

COMPOSITE STEEL ROOF DECK

OWSJ

WET SET DOWELS TO MATCH VERTICAL REINFORCEMENT BETWEEN POUR OR AS SPECIFIED

INTERIOR INSULATION REMOVED AT JOIST LOCATIONS

HORIZ/VERT REINFORCEMENT AS PER CODE OR AS SPECIFIED

1/2" (13mm) GYPSUM BOARD

NUDURA 6" (152mm) STANDARD FORM UNIT

The architecture, engineering, and design of the project using the Nudura products are the responsibility of the project's design professional. All products and systems must comply with local building codes and standards. This detail is for general information and guidance only and Nudura specifically disclaims any liability for the use of this detail. The project design professional determines, in its sole discretion, whether this detail or a functionally equivalent detail is best suited for the project. This detail is subject to change without notice. Contact Nudura to ensure you have the most recent version.

**Non-Combustible Construction**

 Nudura Technical Support: 866-468-6299 International: +1 705-726-9499	Detail: Nudura 6" (152mm) Form Unit, Steel Joist Roof Detail, Bearing Demising Wall		File Name:	 Construction Products Group
	Drawn by: KS	Scale: 1 : 8	Date: 5/17/2022	
<small>tremcoopg.com</small>				